## FUSION BONDED EPOXY COATED C153 DUCTILE IRON MECHANICAL JOINT FITTINGS

## FUSION BONDED EPOXY COATED C153 DUCTILE IRON MECHANICAL JOINT FITTINGS BASIC SPECIFICATIONS

**SIZES:** • 2" - 64"

**MATERIAL:** • Ductile Iron ASTM A536, Grade 65-45-12, 60-42-10 or 70-50-05.

**PRESSURE:** • 350 PSI Water Working Pressure 2"- 24".

250 PSI Water Working Pressure 30"- 48".

150 PSI Water Working Pressure 54"- 64".

**TESTING:** • In accordance with ANSI/AWWA C153/A21.53.

In accordance with UL - FM requirements.

All fittings are hydrostatically tested in accordance with SIGMA Quality Management

Standard.

 All fittings are heat coded to ensure traceability and verification of metallurgical properties in accordance with the prevailing standards and SIGMA Quality Manage-

ment Standards.

**LAYING LENGTH:** • Short body design - straight section of body deleted to provide a compact and lighter

fitting without reducing strength or flow characteristics.

In accordance with ANSI/AWWA C153/A21.53.

**DEFLECTION:** • Maximum allowable deflection for MJ Joint on a full length pipe is as mentioned

below:

1. 3" - 4" = 8 Degrees

2. 6" = 7 Degrees

3. 8" - 12" = 5 Degrees

4. 14" - 48" = 3 Degrees

• SIGMA FBE Coated Fittings are NSF61 and Annex G approved for potable water

applications. The Epoxy Coated Fittings meet or exceed ANSI/AWWA C116/A21.16 and C550 standards (Protective Fusion-Bonded Epoxy Coatings for the Interior and Exterior surfaces of Ductile-Iron and Gray-Iron fittings for water supply service).

FBE coated fittings of SIGMA are available from 2" to 48" in accordance with ANSI/

AWWA C153/A21.53.

• SBR in accordance with ANSI/AWWA C111/A21.11.

Also available in EPDM, NBR and CR.

T-BOLTS:

• Low Alloy corrosion resistant high strength steel in accordance with ANSI/AWWA

C111/A21.11.

**APPROVALS:** • 3"-16" Underwriters Laboratories listed and Factory Mutual Approved.

**STANDARDS:** • Certified to NSF61 Standard including Annex G.

• ANSI/AWWA C153/A21.53 for Compact Ductile Iron Fittings 2"-64" for water and

other liquids.

**INSTALLATION:** • Per ANSI/AWWA C600 and C111 using DIP conforming to C150/C151 and PVC pipe

conforming to C900/C905.







